



| | |
|--------------|-------------------|
| CONTRACTOR: | |
| PROJECT: | DATE: |
| PREPARED BY: | MODEL: MBL-HM-FDR |

SPECIFICATION & FEATURES

Mobile Home Feeder Cable is used to provide power from the electrical disconnect to the distribution panel board in mobile home applications, suitable for direct burial in earth at conductor temperatures not to exceed 90°C.

- Sunlight resistant, moisture resistant and flame retardant insulation.
- Insulation is heavy metal free in compliance with RoHS wet and dry locations.



CERTIFICATIONS/WARRANTY

Listing: UL44/UL854

RoHS: RoHS Compliant

Warranty

Guaranteed for one year from the purchase date of the product, against mechanical defects in manufacturing.

CONSTRUCTION

| | | | |
|----------------------------|---------------------------------------------------|--------------------------------------------------|---------------------------------|
| Max. Rating 600V | Temperature Rating 90°C | Insulation Material POLYETHYLENE (XLP) | Color BLK/BLK/BLK/GRN |
| Length 1000FT | Conductor Material 8000 Series Aluminum | Number Of Conductors 4 | Package Type Reel |



APPLICATION AND PERFORMANCE SPECIFICATION INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTIFICATION

11675 SW TOM MACKIE BLVD. | PORT ST. LUCIE, FL 34987 | P: 772.878.4944 | WWW.RPP-USA.COM



| | |
|--------------|--------|
| CONTRACTOR: | |
| PROJECT: | DATE: |
| PREPARED BY: | MODEL: |

ORDERING INFORMATION

| Part Code | IMS Code | Conductor Size | Strands | Outside Diameter |
|------------------------------|-----------|-----------------|-------------|------------------|
| MBL-HM-FDR-2-2-4-6-A | 0609-1701 | 2-2-4-6 | 7/7/7/7 | 0.944 IN |
| MBL-HM-FDR-2-2-2-4-A | 0609-1704 | 2-2-2-4 | 7/7/7/7 | 0.944 IN |
| MBL-HM-FDR-2/0-2/0-1-4-A | 0609-1707 | 2/0-2/0-1-4 | 18/18/18/7 | 1.301 IN |
| MBL-HM-FDR-4/0-4/0-2/0-4-A | 0609-1710 | 4/0-4/0-2/0-4 | 19/19/18/7 | 1.54 IN |
| MBL-HM-FDR-4/0-4/0-4/0-2/0-A | 0609-1725 | 4/0-4/0-4/0-2/0 | 19/19/19/18 | 1.54 IN |



APPLICATION AND PERFORMANCE SPECIFICATION INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTIFICATION

11675 SW TOM MACKIE BLVD. | PORT ST. LUCIE, FL 34987 | P: 772.878.4944 | WWW.RPP-USA.COM